ಬೆಸ್ಕಂ
BESCOM

ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸಂಪೂರ್ಣ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)

Bengaluru Electricity Supply Company Limited

Telephone No. 080-2225 2128
E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in
*No: BESCOM/GM(QS&S)/DGM-2/AGM-3/BC-35/23-24/*2449
Encl:

O/o General Manager (Ele),
Quality, Standards and Safety
Corporate Office, KR Circle
BESCOM, Bengaluru – 560 001
Date: 18 JAN 2024

CLARIFICATION-I

Sub: Procurement of FRP discharge rod 10 ft, 2 stage.

Ref:
1. T.O. Bid Enquiry No: BESCOM/GM(Q,S&S)/2023-24/17.
2. KPP Potal tender No. BESCOM/2023-24/IND0048.
3. Paper Notification dated 31.12.2023.
4. Pre-bid meeting dated: 10.01.2024.

******

The following amendment pertaining to subject bid enquiry is herewith issued consequent to request from the prospective bidders and deliberations during pre-bid meeting.

Sl No.	Document and Clause No.	As existing	Clarification
1	**Section II ITT, Clause 5.0 Qualifying Requirements, Technical criteria, Sl No.3**	The Bidder should have supplied FRP DISCHARGE ROD 10 ft, 2 stage to any Electrical utilities of PSU/Govt. departments to an extent of atleast 80% of the tendered quantity in any one of the last three financial years (FY 2020-21, FY 2021-22 and FY 2022-23) (In case of Micro and Small Enterprises, 40% of the tendered quantity in any one of the last two financial years (FY 2021-22 and FY 2022-23)). The above supplied FRP DISCHARGE ROD 10 ft,2 stage shall be in satisfactory operation of 12 months as on date of tendering (i.e, date of NIT issued). **Document to be uploaded:** Purchase orders and completion certificates (for the same POs) for having supplied FRP DISCHARGE ROD 10 ft, 2 stage to any Electrical utilities of PSU/Govt. departments issued by an officer not below the rank of Executive Engineer or Equivalent Rank of the concerned electrical utility of PSU/Govt. departments shall be uploaded. Performance Certificate (for the same POs) issued by an officer not below the rank of Executive Engineer or Equivalent Rank of the concerned electrical utility of PSU/Govt. departments for satisfactory operation of minimum of 12 months from the date of supply shall be uploaded.	No Changes

Sl No.	Document and Clause No.	As existing	Clarification
2	**Section VI : TECHNICAL SPECIFICATION OF FRP DISCHARGE ROD- 10 FEET 2 STAGE, Clause 5 C. EARTHING CABLE :**	The Earthing Rod should be provided with ISI marked PVC insulated single core copper conductor of 16sqmm. The cable shall be minimum 10 mtrs in length connected with conductor clamp of Discharge stick and grounding C clamp at both the ends. Both the ends of the earthing cable should be provided with copper lugs crimped with wire.	No Changes

All other terms & conditions for the subject tender remain unaltered.

18/7/24

(S.T Shanthamallappa)
General Manager(Ele)
QS&S, Corporate Office,
BESCOM

Copy to:-

1. PS to Director (Technical), BESCOM, K.R.Circle, Bangalore, to place before the Director (Technical) for kind information.
2. MF/OC.